

SPRINKLERS

HOSE CONNECTIONS
(NO HOSES)

DOUBLE CHECK VALVE ASSEMBLY
OR DOUBLE DETECTOR CHECK
VALVE ASSEMBLY INSTALLED.
ABOVE GROUND IN APPROVED
PREFAB BOX OR IN METRO WATER
SERVICE APPROVED UNDERGROUND
VAULT. (SEE DRAWING)

ABOVE GROUND RPBP

OUTLET GATE VALVE
IN METER BOX

R.O.W.

DOMESTIC WATER
METER BOX

INLET
GATE VALVE

PUBLIC ROAD

R.O.W.

FIRE SERVICE

DOUBLE CHECK OR
DETECTOR CHECK
VALVE ASSEMBLY

PROP. LINE GATE VALVE

TEE

EX. W.M.

T.S. & V.

METRO WATER SERVICES

3" DOMESTIC SERVICE WITH FIRE SERVICE

NOT TO SCALE | DATE: 2/25/05

DWG. NO. SCHEMATIC 3

METRO
WATER SERVICES

Hal Baltrop
LICENSED DISTRIBUTION OPERATOR

Spittle
DIRECTOR OF WATER AND SEWERAGE SERVICES